

Temporary Certificate of Occupancy

Permit #: PRCOM20122246
Address: 308 NW MURRAY RD, LEES SUMMIT, MO 64081
Inspected On: Wednesday, November 26, 2014
Inspected By: Mike Copeland
Expiration Date: 12/22/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Temporary C of O	Wednesday, November 26, 2014

Corrective Action Required:

1	Misc 1	-DECKS CONSTRUCTED WILL REQUIRE LAGS AT BEAM TO POST CONNECTIONS, AND JOIST HANGERS
---	--------	-------------------------------------------------------------------------------------