

Temporary Certificate of Occupancy

Permit #: PRCOM20142412
Address: 206 NW OLDHAM PKWY, LEES SUMMIT, MO 64081204 NW OLDHAM
PKWY, LEES SUMMIT, MO 64081
Inspected On: Tuesday, December 02, 2014
Inspected By: John Borns
Expiration Date: 12/11/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, December 02, 2014

Corrective Action Required:

1	Misc 1	ANSI/ICC 604.5.1: 18" HORIZONTAL GRAB BARS @ RR105 NOT PER CODE & APPROVED DRAWING.
---	--------	---

Corrective Action Required:

2	Misc 1	IPC 420.3: WATER CLOSET SEAT(S) MUST BE COMMERCIAL TYPE WITH OPEN FRONT. SEE WC @ RR106
---	--------	---

Corrective Action Required:

3	Misc 1	NEC 408.4: LABELING OF ELECTRICAL CIRCUIT POSITIONS AT PANEL(S): EACH BREAKER POSITION MUST BE CLEARLY NUMBERED.
---	--------	--

Corrective Action Required:

4	Misc 1	NEC 110-12: UNUSED BREAKER OPENINGS AT ELECTRICAL PANELS MUST BE CLOSED WITH LISTED PLUG.
---	--------	---

