

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20141418, Building Permit - Residential
Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Grading/Excavation/Fill Inspection	Khanh Nguyen	Failed	Tuesday, December 02, 2014

Corrective Action Required

1	Misc 1	-PROVIDE THE SWALE ALONG THE REAR PER PLOT PLAN
---	--------	---

Comments: