

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132440, Building Permit - Commercial
Address: 101 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|-----------|------------------------------|
| Underground Electrical Inspection - Commercial | John Borns | Not Ready | Wednesday, December 03, 2014 |

Partial Correction

1 Misc 1

OK TO COVER WHEN READY: ONE 3" AND ONE 4" SCH 40 PVC CONDUITS FROM BUILDING ENTRY TO POWER POLE AT SW CORNER OF SITE; 1" PVC CONDUIT TO LOCATIONS OF FIVE LIGHT POLES

Corrective Action Required

2 Misc 1

POLE BASE TUBE FORMS NOT BRACED PLUMB. RE-BAR CAGES NOT HUNG WITH MINIMUM 3" CLEARANCE AT BOTTOM. NEED PERMIT PRINTS FOR INSPECTION. GROUNDING SUBJECT TO APPROVAL PER DRAWING WHEN READY.

Comments: