

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20142582, Building Permit - Commercial  
Address: 500 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Passed	Thursday, December 04, 2014

**Comments: OK TO COVER WHEN READY EXPOSED IN-WALL SYSTEMS CONTINGENT ON COMPLETION OF THE FOLLOWING:**

- 1) INSTALL TWO BOCA PLATES AT PVC PIPE PENETRATION OF BOTTOM PLATE IN KITCHEN COUNTER WALL.**
- 2) TIE TOGETHER TOP OF WALL INTERSECTION AT KITCHEN NE.**
- 3) CHECK ALL ELECTRICAL BOXES AND ENSURE EQUIPMENT GROUND CONDUCTORS ARE CONNECTED WITH WIRE NUTS OR CRIMP CONNECTORS -- TWISTING ALONE NOT SUFFICIENT.**