

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142405, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, December 12, 2014

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING
SYSTEMS @ FOLLOWING SPACES: 1C100; 101; **16" CEILING TIE-IN AT 1C146
EAST;**

Partial Correction
2 Misc 1

PRELIMINARY INSPECTION OF SYSTEMS ABOVE MRI ENCLOSURE: 1) REMOVE
ANY REMAINING ABANDONED HANGERS AND MATERIALS 2) ENSURE ALL
ELECTRICAL BOXES ARE DIRECTLY SUPPORTED TO STRUCTURE

Comments: