

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142708, Building Permit - Commercial
Address: 901 NE BLUESTEM DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Failed	Wednesday, December 17, 2014

Corrective Action Required

1	Misc 1	NEC 370-20; IRC E3806.5-6 SET-BACK OF ELECTRICAL RECEPTACLE / SWITCH BOXES: 1/4" MAXIMUM SET-BACK @ NON-COMBUSTIBLE SURFACES. SEE ALL AT RESTROOM.
---	--------	--

Corrective Action Required

2	Misc 1	VACUUM BREAKER BACKFLOW PREVENTION DEVICE REQUIRED AT HOSE BIB IN ROOM ADJACENT TO RESTROOM.
---	--------	--

Corrective Action Required

3	Misc 1	PROVIDE FULL SET OF CITY-STAMPED PERMIT PRINTS AT RE-INSPECTION.
---	--------	--

Comments: