

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142991, Building Permit - Commercial
Address: 516 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	John Borns	Passed	Tuesday, December 23, 2014

Comments: INSPECTION OF TRENCHED CONDUIT WAS PARTIAL SINCE SUBSTANTIAL PORTIONS WERE TRENCHED AND COVERED WITHOUT APPROVAL. CLOSE PERMIT.