

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142405, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Wednesday, December 24, 2014

Partial Correction
1 Misc 1

FOLLOWING SPACES OK FOR USE & OCCUPANCY: 1C100; 101; 124; 131; 183A;
183B; 215; 215A; 215B; 221;

**[160 & ADJACENT ALCOVE OK CONTINGENT ON FIRE DEPARTMENT
APPROVAL**

Above Ceiling Inspection	John Borns	Partial	Wednesday, December 24, 2014
-------------------------------------	------------	---------	------------------------------

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING
SYSTEMS @ FOLLOWING SPACES: 1C100; 101; 16" CEILING TIE-IN AT 1C146
EAST; **160**;

**ALCOVE ADJACENT TO 160 OK TO COVER AFTER TWO J-BOXES ARE FULLY
MADE-UP AND CLOSED.**

Comments: