



11656 W. 75th Street
Shawnee, KS 66214

P: (913) 631-2222
D: (800) 780-8608

HD Engineering & Design, Inc.

Solutions for all your engineering and design needs

RECEIVED

December 18, 2014

DEC 29 2014

R.M. Standard
11233 Nail Avenue
Suite 130
Leawood, KS 66211

CHIEF OF POLICE
CODES ADMINISTRATION

Re: 513 NE Promised View Dr

Our firm examined the footing preparation today at 513 NE Promised View Dr for which permit PRES14-3037 has been issued. The forms and reinforcement were found to be clean, well aligned, and placed per the approved plans on site. Our firm does not perform civil engineering and has not been contacted to verify adequate removal and termination of the pipe that previously ran under the site.

Proper termination and removal of the pipe should be verified by a civil engineering firm prior to backfill.

At the time of our inspection erosion control was in place and functional per the APWA residential standards.

Our firm recommends approval of the footing preparation for the placement of concrete.

Very truly yours,
HD ENGINEERING & DESIGN, INC.


Todd Langenhorst, Senior Field Tactics Liaison

Chris Saathoff, P.E., LEED-AP

