

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20143261, Building Permit - Residential
Address: 613 NW TIMBER RIDGE TRL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	John Borns	Passed	Tuesday, December 30, 2014

**Comments: NEW FINISHED BEDROOM APPROVED FOR USE. ARC FAULT CIRCUIT BREAKER IS
RECOMMENDED; REQUIRED IN NEW CONSTRUCTION UNDER CURRENT ELECTRICAL CODE. CLOSE
PERMIT.**