

Temporary Certificate of Occupancy

Permit #: PRCOM20143426
Address: 1127 NE RICE RD, LEES SUMMIT, MO 64086
Inspected On: Friday, January 02, 2015
Inspected By: Khanh NguyenKhanh Nguyen
Expiration Date: 1/30/2015 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Passed	Friday, January 02, 2015
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, January 02, 2015

Corrective Action Required:

1	Misc 1	-CORRECT ISSUES FROM FIRE DEPT. LIST -INSTALL NO SMOKING SIGNAGE AT FRONT -SHALL PATCH ALL HOLES AND PENETRATIONS OF TENANT SEPARATION WALL ABOVE CEILING SPACE -SHALL SECURE ALL MC WIRING WITHIN 12" OF BOXES -SHALL PROPERLY SUPPORT ALL LOW VOLTAGE WIRING IN A NEAT AND WORKMAN-LIKE MANNER. CANNOT LAY LOW VOLTAGE WIRING ON CEILING GRID
---	--------	---