

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141072, Building Permit - Commercial
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Friday, January 02, 2015

Corrective Action Required
1 Misc 1

PARTIAL INSPECTION-
-SHEAR WALL EXTERIOR PLYWOOD NAIL PATTERN
BSMT CENTER NORTH SHEAR WALL OK TO INSULATE

Comments: