

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20141418, Building Permit - Residential  
Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, January 07, 2015

Corrective Action Required

1	Misc 1	-OBTAIN PERMIT FOR DECK -SOD, SPLASHBLOCKS -UNDERSLAB WAS FAILED AND NOT APPROVED FOR CONCRETE POUR -SIDEWALK NOT APPROVED ON RECORD -INSTALL SAFETY TEMPERED GLASS WINDOWS AT HYDROTUB *FROM ALLROUGH
---	--------	--

\*\*INSPECTION WAS NOT DONE INSIDE. NO ACCESS CODE TO GET INSIDE

<b>Grading/Excavation/Fill Inspection</b>	Khanh Nguyen	Passed	Wednesday, January 07, 2015
---	--------------	--------	-----------------------------

Comments: