

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142967, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, Unit:200, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Wednesday, January 07, 2015
Partial Correction 1 Misc 1		FOLLOWING SPACES OK FOR USE AND OCCUPANCY: 2E57 & 69 (DOCUMENTATION OF TEST OF NEW SMOKE DETECTOR @ 69 TO BE PROVIDED TO CPT DIR @ LSFD);	
Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Wednesday, January 07, 2015
Corrective Action Required 1 Misc 1		phase-1 of 2 - confirmation from alarm installer that the new(added) smoke detection in room 2E69 has been installed, programed and tested.	

Comments: