

Punch List

Date: Wednesday, January 07, 2015

To: PARIC CORPORATION
77 WESTPORT PLAZA, SUITE 250
ST LOUIS, MO 63146
Fax # <NO FAX NUMBER>
Emery Sapp & Son Construction Co.
<NO STREET ADDRESS>

Fax # <NO FAX NUMBER>

Re: Certificate of Substantial Completion for:
Public Works Infrastructure Permit - Commercial, Development-Complete
PRPWFC20142976

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813.

PUNCH LIST CORRECTIONS:

- 1) Remove and replace three public ADA Ramps to federal standards. Two Ramps on the north entrance and one ramp on the south side of the southern entrance.
- 2) Establish proper vegetation on all bare ground areas disturbed by construction activities.
- 3) Maintain erosion control measures until proper vegetation is established.

, Developer
(Signature & Date)

Bob Burns, Public Works Inspector
(Signature & Date)

Original: Public Works Inspections File

Copy:

Developer
Contractor

Public Works Development Engineering Manager
Design Engineer / Architect