

**PUBLIC WORKS ENGINEERING DIVISION**

**Punch List**

**Date:** Wednesday, January 07, 2015

**To:** PARIC CORPORATION  
77 WESTPORT PLAZA, SUITE 250  
ST LOUIS, MO 63146  
Fax # <NO FAX NUMBER>  
Emery Sapp & Son Construction Co.  
<NO STREET ADDRESS>

Fax # <NO FAX NUMBER>

**Re: Certificate of Substantial Completion for:**  
Public Works Infrastructure Permit - Commercial, Development-Complete  
PRPWFC20142976

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813. Failure to complete all items will result in a freeze of building permits until all items are corrected and a Certificate of Final Acceptance is issued.

**PUNCH LIST CORRECTIONS:**

- 1) Remove and replace three ADA Ramps that do not meet federal specifications. Two ADA ramps at the north entrance and one ADA ramp on the south side of the southern entrance.
- 2) Establish proper vegetation on all areas disturbed by construction activities.
- 3) Maintain erosion control devices until proper vegetation is established.

---

, Developer  
(Signature & Date)

---

Bob Burns, Public Works Inspector  
(Signature & Date)

Original: Public Works Inspections File

Copy:

Developer  
Contractor

Public Works Development Engineering Manager  
Design Engineer / Architect