

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142405, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|---|----------------------------|
| Above Ceiling Inspection | John Borns | Partial | Thursday, January 08, 2015 |
| Partial Correction 1 Misc 1 | | OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 1C100; 101; 16" CEILING TIE-IN AT 146 EAST; 160; ALCOVE ADJACENT TO 160; AFFECTED AREAS IN 140/143/146; 141; 142 | |
| Final Building Inspection - Commercial | John Borns | Partial | Thursday, January 08, 2015 |
| Partial Correction 2 Misc 1 | | FOLLOWING SPACES OK FOR USE & OCCUPANCY: 1C100; 101; 124; 131; 183A; 183B; 215; 215A; 215B; 221; 160 & ADJACENT ALCOVE; AREAS AFFECTED AT 140/143/146 OK FOR PLACEMENT OF FURNITURE. TESTING OF EMERGENCY CIRCUIT ELECTRICAL RECEPTACLES SUBJECT TO VERIFICATION. | |

Comments: