

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130422, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Khanh Nguyen	Partial	Friday, January 09, 2015

Corrective Action Required

1	Misc 1	STAIR HEADROOM CLEARANCE FIX AT NORTH STAIR ENCLOSURE- FILL IN GAP BETWEEN HANGER AND BEAM METAL PLATE
---	--------	--

Comments: