

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122453, Building Permit - Commercial
Address: 310 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Monday, January 12, 2015

Partial Correction

1 Misc 1

Corrective Action Required

2 Misc 1

OK FOR OCCUPANCY: N-S WING UNITS 101-114; UNIT 100;

KITCHEN:

1) FOUR-PLEX ELECT RECEPT LEFT OF REFRIGERATOR NOT GFI-PROTECTED.

Comments: