

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140231, Building Permit - Commercial  
Address: 220 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Tuesday, January 13, 2015

Corrective Action Required

1	Misc 1	1) EXISTING GUARD AROUND EXTERIOR STAIR TO BASEMENT NOT 42" HIGH AND NOT CLOSED TO LESS THAN 4" TO AT LEAST 36" HIGH PER IBC. 2) GUARD AT INTERIOR STAIR TO BASEMENT NOT 42" HIGH PER IBC. 3) WIRE GLASS VISION PANELS NOT COMPLIANT WITH CURRENT CODE. 4) LAV APRONS AT RESTROOMS NOT ANSI COMPLIANT.
---	--------	---

Comments: