



PUBLIC WORKS ENGINEERING DIVISION

Punch List

Date: Wednesday, January 14, 2015

To: PARIC CORPORATION
77 WESTPORT PLAZA, SUITE 250
ST LOUIS, MO 63146

Re: Certificate of Substantial Completion for: John Knox Village Parking Lot Reconstruction 400 NW Murray Rd.

Public Works Infrastructure Permit - Commercial, Development-Complete
PRPWFC20142976

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813.

PUNCH LIST CORRECTIONS:

- 1) Remove and replace three ADA Ramps that do not meet federal specifications. Two ADA Ramps at the north entrance and one ADA ramp on the south side of the southern entrance.
- 2) Establish proper vegetation on all areas disturbed by construction activities.
- 3) Maintain erosion control devices until proper vegetation is established.

, Developer
(Signature & Date)

Bob Burns, Public Works Inspector
(Signature & Date)

Original: Public Works Inspections File

Copy:

Developer
Contractor

Public Works Development Engineering Manager
Design Engineer / Architect