

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141075, Building Permit - Commercial
Address: 3321 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mark Harding	Failed	Thursday, January 15, 2015

Corrective Action Required

1	Misc 1	UPPER PORTION EAST SIDE- Failed- see clearance between foam board and rebar. clearance between rebar and ground. spacing blocks are not 3" . missing section of rebar on south side back of elevator location. recall when ready do not pour.
---	--------	--

Comments: