

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

January 26, 2015

LANGSFORD DEVELOPMENT INC
616 SW 3RD ST
LEES SUMMIT, MO 64063

Permit No: PRCOM20150084
Project Title: 651 PROJECT
Project Address: 651 SW 2ND ST, LEES SUMMIT, MO 64063
Parcel Number: 61330168900000000
Location: RNG-31 TWP-47 SEC-06 PT SW 1/4 DAF: BEG AT A PT 1150' W OF SE COR SD SW 1/4 TH N 28' M/L TO N ROW LI OF 3RD ST & TRU POB TH CONT N 220' TH E 130' TO SW COR LOT 58 ROBIN HILLS TH N 125' TO S ROW LI OF
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: INTERIOR REMODEL FOR CHANGE OF TENANT - INCLUDES REMOVING WALLS TO OPEN UP SPACE AND RELATED ELECTRICAL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors	Reviewed By: Joe Frogge	Approved
Building Plan Review	Reviewed By: Joe Frogge	Approved
Fire Plan Review	Reviewed By: Brian Austerman	Approved

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Provide addressing on front and rear doors

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a 5lb ABC type extinguisher

_____ Approved to issue per the listed conditions.

_____ Do not issue per the listed conditions.

- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant	Date
------------------------	------

Print Applicant Name	CompanyName
----------------------	-------------

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.