

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142967, Building Permit - Commercial

Address: 120 NE SAINT LUKES BLVD, Unit:200, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

In-wall Inspection

John Borns

Partial

Thursday, January 29, 2015

Partial Correction

1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL
SYSTEMS AT FOLLOWING SPACES: 2E69; **X-RAY 2E81 AFTER ONE NOTCHED
STUD IS REINFORCED AND DOOR FRAME ANCHORAGE IS IMPROVED;**

Comments: