

PLAN REVIEW CONDITIONS

February 10, 2015

SFCS ARCHITECTS
1927 SOUTH TRYON ST, SUITE 207
CHARLOTTE, NC 28203

Permit No: PRCOM20150016
Project Title: JOHN KNOX VILLAGE COURTYARDS COMMONS BUILDING AND ELEVATED WALKWAY
Project Address: 512 NW MURRAY RD, LEES SUMMIT, MO 64081
Parcel Number: 62120018200000000
Location: JOHN KNOX RETIREMENT VILLAGE-12TH PLAT---LOT B
Type of Work: ADDITION COMMERCIAL
Occupancy Group: MIXED OCCUPANCY
Description: COMMON AREA SERVING ATTACHED MULTI-FAMILY INDEPENDENT SENIOR LIVING -
INCLUDES KITCHEN, DINING, OFFICE AND GATHERING AREAS - ALSO INCLUDES ELEVATED
WALKWAY CONNECTION TO PAVILION

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment for informational purposes.

3. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment for informational purposes.

5. Copies of the engineered truss package were not provided at the time of permit application.

Action required: Provide roof and floor truss packages or defer to construction. Approved truss packages must be on site for inspections.

2/10/15 - deferred to construction

7. 2012 IBC 1004.3 - Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Action required: Comment for informational purposes. To be verified during inspections.

14. 2012 IBC 1013.6 Mechanical equipment. Guards shall be provided where appliances, equipment, fans, roof hatch openings or other components that require service are located within 10 feet of a roof edge or open side of a walking surface and such edge or open side is located more than 30 inches above the floor, roof or grade below. The guard shall be constructed so as to prevent the passage of a sphere 21 inches in diameter. The guard shall extend not less than 30 inches beyond each end of such appliance, equipment, fan, or component.

Action required: Comment for informational purposes. May be verified during inspections.

15. Additional information required.

Action required: Provide verification that salon will not have manicure or pedicure stations.

2/10/15 - Wall exhaust grille added near manicure station. Pedicure chair not found on drawings. Given that furniture plans sometimes vary, this will be verified in the field. Exhaust grilles must be at source.

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

2. 2012 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Occupant loads shall be posted in assembly areas

3. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide engineer stamped alarm plans for approval

4. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide engineer stamped sprinkler plans for approval

5. 904.11.5 Portable fire extinguishers for commercial cooking equipment.

Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving solid fuels or vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher in accordance with Section 904.11.5.1 or 904.11.5.2, as applicable.

904.11.5.1 Portable fire extinguishers for solid fuel cooking appliances.

All solid fuel cooking appliances, whether or not under a hood, with fireboxes 5 cubic feet (0.14 m³) or less in volume shall have a minimum 2.5-gallon (9 L) or two 1.5-gallon (6 L) Class K wet-chemical portable fire extinguishers located in accordance with Section 904.11.5.

904.11.5.2 Class K portable fire extinguishers for deep fat fryers.

1. For up to four fryers having a maximum cooking medium capacity of 80 pounds (36.3 kg) each: one Class K portable fire extinguisher of a minimum 1.5-gallon (6 L) capacity.
2. For every additional group of four fryers having a maximum cooking medium capacity of 80 pounds (36.3 kg) each: one additional Class K portable fire extinguisher of a minimum 1.5-gallon (6 L) capacity shall be provided.
3. For individual fryers exceeding 6 square feet (0.55 m2) in surface area: Class K portable fire extinguishers shall be installed in accordance with the extinguisher manufacturer's recommendations.

6. 904.11.1 Manual system operation.

Exception: Automatic sprinkler systems shall not be required to be equipped with manual actuation means.

Show location of manual pull device for the hoods. K class extinguisher shall be mounted below the pull

7. Duct detection required for units over 2,000 cfm. Activation shall shut down the unit and transmit a supervisory signal to the panel

8. Will generator be natural gas or diesel?

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

____ Approved to issue per the listed conditions.

____ Do not issue per the listed conditions.

____ Approved to construct foundation only per the listed conditions.

____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date _____

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.