

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20132689, Building Permit - Residential
Address: 301 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Wednesday, February 11, 2015

Comments: OK TO POUR WHEN READY TRENCHED FOOTING 12" WIDE x >=36" DEEP W/ TWO #4 REBAR NEAR TOP + FLOOR DOWELS TO BE STUCK.