

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150205, Building Permit - Commercial  
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, February 11, 2015
Partial Correction 1      Misc 1		INSTALLATION CONFIGURATION OBSERVED W/ R-7 FACILITIES PERSONNEL. CONDUIT TRENCHED AND MOSTLY COVERED FROM LOAD CENTER TO SIGN LOCATION. SIGN BASE WAS POURED BY INFINITY SIGN W/O INSPECTION. R-7 TO REQUEST INSPECTION WHEN CONDUCTORS ARE BEING PULLED & TERMINATED.	
<b>Rough Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, February 11, 2015
Partial Correction 1      Misc 1		INSTALLATION CONFIGURATION OBSERVED W/ R-7 FACILITIES PERSONNEL. CONDUIT TRENCHED AND MOSTLY COVERED FROM LOAD CENTER TO SIGN LOCATION. SIGN BASE WAS POURED BY INFINITY SIGN W/O INSPECTION. 5/8" GROUND ROD AND #4 G.E.C. IN PLACE OK TO COVER WHN READY. R-7 TO REQUEST INSPECTION WHEN CONDUCTORS ARE BEING PULLED & TERMINATED.	

**Comments:**