

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143142, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Wednesday, February 11, 2015

Partial Correction  
1 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE BUILDING PERIMETER GRADE BEAM AS FOLLOWS WITH POINTS WRITTEN ON PERMIT PRINTS: FROM (1) TO (2); FROM (2) TO (4), WITH BULKHEAD BLOCK-OUTS LEFT AT (3) FOR CONNECTION OF UFER GROUND G.E.C.; FROM (4) CCW TO (5); FROM (5) CCW TO (6); **SECTION PREVIOUSLY BLOCKED-OUT WHERE UFER GROUND JUMPER IS NOW TERMINATED ON LONGITUDINAL RE-BAR;**

Partial Correction  
2 Misc 1

**OK TO POUR WHEN READY GRADE BEAMS FOR PORCH SLABS:**  
**A) ONE @ EAST END**  
**B) NORTH SIDE FROM EAST END: #1**  
**C) SOUTH SIDE FROM EAST END: #1, 2,3,**

Partial Correction  
3 Misc 1

**OK TO POUR WHEN READY ELEVATOR PIT SLAB WITH SUMP PIT**

**Comments:**