

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150189, Building Permit - Commercial
Address: 1211 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Thursday, February 12, 2015

Corrective Action Required

1	Misc 1	-SHALL SECURE ABOVE-CEILING BOXES AND WIRING PER CODE. BOXES SHALL BE SECURED AND MC CABLE MUST BE SECURED WITHIN 12" OF BOXES, EXCEPT WHEN CONNECTED DIRECTLY TO CEILING LUMINAIRE WITHIN 6 FT OF BOXES -OPEN ELECTRICAL BOX SHALL BE CLOSED
---	--------	--

Comments: