



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20141214	Date:	February 12, 2015
Project Title:	ABUNDANT LIFE BAPTIST CHURCH AUDITORIUM AND EDUCATION FACILITIES	Applicant:	JAYHAWK FIRE SPRINKLER CO INC
Location:	304 SW PERSELS RD, LEES SUMMIT, MO 64081		PO BOX 8458 TOPEKA, KS 66608
Type of Work:		Primary:	(785) 232-0975
Occupancy Group:	A-3		
Description:	AUDITORIUM AND EDUCATION FACILITIES FOR CHURCH		

Mike Weisenborn 01/12/2015 2:23 PM - THE ACTUAL AREA OF THE BUILDING PERMITTED IS 98,199 SQUARE FEET OF WHICH 69,078 SQUARE FEET IS FINISHED. THIS IS FOR THE AUDITORIUM. THE REMAINING 29,121 SQUARE FEET OF THE EDUCATIONAL WING IS SHELL SPACE AND WILL BE FINISHED AS FUNDING ALLOWS.

Mike Weisenborn 05/22/2014 11:19 AM - WATER SERVICE AND BUILDING SEWER INSPECTIONS PERFORMED BY PUBLIC WORKS
Construction Type: Type IIA (1 hour)
Map Page: 195P

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.