

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150051, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:200, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Tuesday, February 17, 2015

Corrective Action Required

1 Misc 1

LSCO SEC 7-142; IBC 106: PERMIT DRAWINGS NOT FOUND ON SITE. NO INSPECTIONS WITHOUT CITY-STAMPED PERMIT PRINTS.

Corrective Action Required

2 Misc 1

NOTE: NEC 334-10 SECURING / SUPPORT OF MC ELECTRICAL CABLE: SECURE WITHIN 12" OF BOXES AND SUPPORT AT 6' MAX INTERVALS THEREAFTER. COLORADO JIMS DO NOT SECURE MC TO RESIST TUGGING. USE CLAMPS THAT FASTEN MC IN PLACE WITHIN 12" OF BOX ENTRY.

Comments: