

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150051, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:200, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Wednesday, February 18, 2015
Above Ceiling Inspection	John Borns	Failed	Wednesday, February 18, 2015

Corrective Action Required

1 Misc 1

FASTENING OF LIGHT-GAUGE STEEL STUDS ACTING IN TENSION: SCREW BOTH FLANGES TO TOP TRACKS. SEE AT HANGING ATRIUM SOFFIT.

Comments: OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS THROUGHOUT.