

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141078, Building Permit - Commercial
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Failed	Friday, February 20, 2015

Corrective Action Required

1	B705 FIRE WALLS	INWALL-PRE ROCK INSPECTION: GARAGE PLUMBING CHASE, SHOWER WALLS, FURNACE ROOM WALL
		GARAGE- 1ST- 2ND- 3RD- 4TH-

Comments: