



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

February 20, 2015

GUENTHER MILLS KEATING ARCHITECTS
6532 BLUE RIDGE CUTOFF, RAYTOWN MO
64133

Permit No: PRCOM20150269
Project Title: EAGLE CREEK CHURCH VIDEO VENUE
Project Address: 1469 SW MARKET ST, LEES SUMMIT, MO 64081
Parcel Number: 61800320800000000
Location: SOUTH PORT BUSINESS PARK LOT 12-A LOT 12-A
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR WORSHIP, RECREATION OR AMUSEMENT
Description: INTERIOR ALTERATIONS TO CHANGE TENANT FROM RESTAURANT TO REMOTE CHURCH VIEWING VENUE - ALTERATIONS INCLUDE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

1. 2012 IBC 1004.3 - Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Action required: Post occupant load. To be verified during inspections.

2. Miscellaneous comment.

Action required: Provide electrical design or detailed scope of work from licensed electrician.

Fire Plan Review

Reviewed By: Brian Austerman

Approved

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7

mm).

Provide addressin on all doors, if not already existing

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Existing type 1 hood shall be maintained and have current certification at time of final

3. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide 5lb ABC type extinguishers for the building and a "K" class extinguisher for the hood

4. Per phone conversation with Steve Guenther (GMK) the smoke detection will be omitted

5. Provide panic hardware on marked exit doors. Verified at inspection

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.