

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20141418, Building Permit - Residential
Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, February 23, 2015

Corrective Action Required

1	Misc 1	-SIDEWALK NOT APPROVED ON RECORD. CONTACT PW ROW INSPECTOR **I AM WAITING FOR PW TO UPDATE THE DATA BASE -SEAL ALL EXTERIOR WALL PENETRATIONS, INCLUDING THE PENETRATION BY A/C COOLANT LINE; SEAL EXTERIOR LIGHTS **NOT DONE -PROVIDE ACCESS TO HYDROMASSAGE TUB **CUT OUT THE CONCRETE BOARD SO I CAN HAVE ACCESS TO THE EQUIPMENTS
---	--------	--

Comments: