



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20141214	Date:	February 24, 2015
Project Title:	ABUNDANT LIFE BAPTIST CHURCH AUDITORIUM AND EDUCATION FACILITIES	Applicant:	ATRONIC ALARMS INC 8220 MELROSE DR LENEXA, KS 66214
Location:	304 SW PERSELS RD, LEES SUMMIT, MO 64081		
Type of Work:		Primary:	(913) 362-0000
Occupancy Group:	A-3		
Description:	AUDITORIUM AND EDUCATION FACILITIES FOR CHURCH		
Construction Type:	Type IIA (1 hour)		
Map Page:	195P		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Add an annunciator panel in the sprinkler room
2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing
3. Provide a smoke detector within 10' of the FACP
4. Add or replace heat detector with a smoke detector in the elevator equipment room
5. Confirm the lack of need for smoke detection in the first floor alternate. Although it is labeled as worship it appears to be of similar use of the second floor alternate which has smoke detection
6. Outside horn strobe shall activate on a waterflow alarm only
7. Silencing the system shall terminate all horns, strobes, and voice messaging

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.