

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150084, Building Permit - Commercial  
Address: 651 SW 2ND ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Passed	Wednesday, February 25, 2015

**Comments: OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS.**

**PRELIMINARY OBSERVATIONS FOR OCCUPANCY INSPECTION:**

- RECOMMEND NEW, LEGIBLE, CURRENT ELECTRICAL PANEL SCHEDULE
- LEAVE NO UNUSED OPENINGS AT PANEL DEAD FRONT. USE LISTED PLUGS.
- CHECK ALL ELECTRICAL BOXES: MAXIMUM BOX SET-BACK AT NON-COMBUSTIBLE WALL SURFACES IS 1/4"; USE SPARK RINGS TO CORRECT. EQUIPMENT GROUND CONTINUITY MUST BE BY WIRE NUT OR CRIMP CONNECTOR. LEAVE NO CONDUCTOR ENDS UNTERMINATED OR WITHOUT WIRE NUT. DEVICES MUST BE SECURED SOLID TO BOX, WITH NO "SOFTNESS" NOR SIDE-TO-SIDE MOVEMENT; USE YOKE SPACERS WHERE NEEDED.

**REQUEST OCCUPANCY INSPECTION AT LEAST TWO DAYS IN ADVANCE.**