

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143253, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, Unit:240, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Friday, February 27, 2015

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: **252; 256; 259; 260; 262;**

NOT APPROVED:  
239 - WORK IN PROGRESS  
246 - RESTORE FIRE-PROOFING AT WF BEAM  
261 - RESTORE RETURN AIR DUCT INSULATION

**Comments:**