

CODES ADMINISTRATION

Certificate of Occupancy

Permit #: PRCOM20150084

Address: 651 SW 2ND ST, LEES SUMMIT, MO 64063

Inspected On: Monday, March 02, 2015

Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Borns Full C of O Monday, March 02,

Codes Commercial 2015

Comments: CONTINGENT ON WIRE CONNECTORS TO BE PLACED ON UNTERMINATED "ABANDONED" CONDUCTORS IN ELECT BOX AT NEW WEST DEMISING WALL SOUTH.