

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141078, Building Permit - Commercial  
Address: 3351 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Mike Copeland	Partial	Monday, March 02, 2015

### Corrective Action Required

1	Misc 1	GARAGE-framing 1ST -partial 2ND-partial 3RD- 4TH-
---	--------	---

### Partial Correction

2	Misc 1	MIKE COPELAND 03/02/2015 11:18 AM -LOWER LEVEL SHEAR WALL AT ELEVATOR SHAFT NEED TO INSTALL HOLD DOWNS PER PLANS. OTHER SHEAR WALLS APPROVED. -FIRST FLOOR MECHANICAL ROOMS OKAY TO ONE SIDE ROCK. NEED TO FIRESTOP SPRINKLER
---	--------	---

### Comments: