

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132440, Building Permit - Commercial
Address: 101 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Tuesday, March 03, 2015

Corrective Action Required

8 Misc 1

"NO SMOKING" SIGN REQ'D @ PUBLIC ENTRANCES

Corrective Action Required

9 Misc 1

ADDRESS # REQ'D @ 3RD STREET ELEVATION AND AT REAR.

Corrective Action Required

10 Misc 1

INSTALLATION OF LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED. PER NEC 600.3, IF INTERNALLY LIGHTED MUST BE SHOP-LABELED. INSTALL NO NON-LABELED SIGN.

Corrective Action Required

1 Misc 1

FINISH SITEWORK NOT READY FOR INSPECTION

Corrective Action Required

2 Misc 1

BUILDING EXTERIOR:
- WALL PENETRATIONS TO BE SEALED

Corrective Action Required

3 Misc 1

ROOFTOP:
- GFI RECEPTACLE REQ'D W/I 10M OF MECH UNITS
- PITCH POCKET NOT SEALED

Corrective Action Required

4 Misc 1

EXPANSION TANK REQUIRED AT WATER HEATER

Corrective Action Required

5 Misc 1

EXCESSIVE SET-BACK OF ELECT BOX @ 102 EAST WALL IN BASE CABINET BACKSPLASH

Corrective Action Required

6 Misc 1

LOOSE/SOFT ELECT RECEPT @ 109 NORTH WALL

Corrective Action Required

7 Misc 1

ELECT RECEPT NOT HOT FOR TEST @ PROCEDURE 107 NW WEST WALL

Comments: ABOVE ITEMS ARE PRELIMINARY, COURTESY OBSERVATIONS ONLY AND ARE NOT TO BE CONSTRUED AS FINAL INSPECTION.

