



CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

March 05, 2015

HGK CONSTRUCTION MANAGEMENT INC
6532 BLUE RIDGE CUTOFF
RAYTOWN, MO 64133

Permit No: PRCOM20150269
Project Title: EAGLE CREEK CHURCH VIDEO VENUE
Project Address: 1469 SW MARKET ST, LEES SUMMIT, MO 64081
Parcel Number: 61800320800000000
Location: SOUTH PORT BUSINESS PARK LOT 12-A LOT 12-A
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR WORSHIP, RECREATION OR AMUSEMENT
Description: INTERIOR ALTERATIONS TO CHANGE TENANT FROM RESTAURANT TO REMOTE CHURCH
VIEWING VENUE - ALTERATIONS INCLUDE SOME ELECTRICAL, REMOVAL OF FURNITURE,
CONSTRUCTION OF RAISED PLATFORM

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

1. 2012 IBC 1004.3 - Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Action required: Post occupant load. To be verified during inspections.

Fire Plan Review

Reviewed By: Brian Austerman

Approved

Licensed Contractors

Reviewed By: Joe Frogge

Approved

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.