

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150011, Building Permit - Commercial  
Address: 512 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection</b> <b>- Commercial</b>	John Borns	Failed	Thursday, March 05, 2015

Corrective Action Required

1	Misc 1	SINGLE CURTAIN OF #5 RE-BAR VERT, #4 HORIZ @ 12" O/C. EXPOXIED DOWELS INSPECTED BY TERRACON. FOOTING NOT PER DRAWING. NO REVISION RECEIVED.
---	--------	---

**Comments:**