

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143142, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mike Copeland	Partial	Monday, March 09, 2015

Partial Correction  
1 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE BUILDING PERIMETER GRADE BEAM AS FOLLOWS WITH POINTS WRITTEN ON PERMIT PRINTS:  
FROM (1) TO (2); FROM (2) TO (4), WITH BULKHEAD BLOCK-OUTS LEFT AT (3) FOR CONNECTION OF UFER GROUND G.E.C.; FROM (4) CCW TO (5); FROM (5) CCW TO (6); FROM (5) CCW TO (6); FROM (1) CW TO (7) TO (8) INCLUDING SPREAD FOOTINGS; FROM (6) TO (8);

Partial Correction  
2 Misc 1

OK TO POUR WHEN READY GRADE BEAMS FOR PORCH SLABS:  
A) ONE @ EAST END  
B) NORTH SIDE FROM EAST END: #1, 2, 3, 4, 5  
C) SOUTH SIDE FROM EAST END: #1, 2,3, 4, 5

Partial Correction  
3 Misc 1

OK TO POUR WHEN READY ELEVATOR PIT SLAB WITH SUMP PIT

Partial Correction  
4 Misc 1

-THREE REMAINING GRADE BEAMS FOR STOOPS, 2 NORTH WEST AND ONE SOUTH WEST APPROVED TO POUR

**Comments:**