220 SE GREEN ST. P. O. BOX 1600

ADDRESS: 1051 SE OLDHAM PKWY

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION

PHONE: 816-969-1200 FAX: 816-969-1201

Emergency Call-Out Inspection Report

PROPERTY OWNER : DODGE DEALER	
MIKE MAANANU(MANAGER)-5259825	
PHONE#: 525-9825	
Time of Call to respond: 7:08PM	
Time of Arrival on scene:7:30PM	
Description: Electrical issue in parking lot lights	
Location of Damages: west of main building east side of wash bay.	
Light pole base was relocated when wash bay was installed. Electrical i	n ground where old pole base was located was
Full of water. 3 sets of conduit, wire nuts and electrical tape in water.	
Panel south east corner of main building PL1. Breakers on right side of	panel to remain off until inspected by licensed
Electrician.	
Electrical permit required.	
Gas Service:	
Electrical Service:	
Water Service:	
List of placards posted: inspected	
Permits required: electrical	
Time Departed:8:00pm	
INSPECTOR: mark harding	DATE:3/7/15