

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150269, Building Permit - Commercial  
Address: 1469 SW MARKET ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	Mark Harding	Failed	Tuesday, March 10, 2015

Corrective Action Required

1	Misc 1	on electrical junction box is covered by the floor framing- open up wall or box for inspection. no electrical boxes can be covered by floor framing.
---	--------	---

<b>Rough Framing Inspection - Residential</b>	Mark Harding	Failed	Tuesday, March 10, 2015
---	--------------	--------	-------------------------

Corrective Action Required

1	FRAMING/STRUCTURE	- provide plans showing joist spacing and material to be used. - egress door blocked in and removed on north east wall. Submit revised plans with approval from plan review. Do Not Cover.
---	-------------------	--

Comments: