

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	Mike Copeland	Partial	Tuesday, March 10, 2015

Partial Correction

1 THE FOLLOWING AREAS -UNDERSLAB APPROVED TO COVER EAST OF ROOMS AE124 AND AE113  
ARE APPROVED

**Comments:**