

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143142, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mark Harding	Partial	Thursday, March 12, 2015

Partial Correction		
4	Misc 1	-THREE REMAINING GRADE BEAMS FOR STOOPS, 2 NORTH WEST AND ONE SOUTH WEST APPROVED TO POUR
Partial Correction		
3	Misc 1	OK TO POUR WHEN READY ELEVATOR PIT SLAB WITH SUMP PIT
Partial Correction		
2	Misc 1	OK TO POUR WHEN READY GRADE BEAMS FOR PORCH SLABS: A) ONE @ EAST END B) NORTH SIDE FROM EAST END: #1, 2, 3, 4, 5 C) SOUTH SIDE FROM EAST END: #1, 2,3, 4, 5
Partial Correction		
1	Misc 1	OK TO POUR WHEN READY SECTIONS OF CONCRETE BUILDING PERIMETER GRADE BEAM AS FOLLOWS WITH POINTS WRITTEN ON PERMIT PRINTS: FROM (1) TO (2); FROM (2) TO (4), WITH BULKHEAD BLOCK-OUTS LEFT AT (3) FOR CONNECTION OF UFER GROUND G.E.C.; FROM (4) CCW TO (5); FROM (5) CCW TO (6); FROM (5) CCW TO (6); FROM (1) CW TO (7) TO (8) INCLUDING SPREAD FOOTINGS; FROM (6) TO (8);
Corrective Action Required		
5	THE FOLLOWING AREAS ARE APPROVED	INTERIOR PIERS EAST TO WEST-7 PIERS A,B,C,D,E,F,G-

Underground Electrical Inspection - Commercial	Mark Harding	Partial	Thursday, March 12, 2015
---	--------------	---------	--------------------------

Corrective Action Required		
1	THE FOLLOWING AREAS ARE APPROVED	SOUTH EAST ELECTRICAL ROOM-10' OUT-3-4",1-3"

FROM ROOM TO NORTH EXTERIOR WALL-
2-1",3-3/4"

Comments: