

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143272, Building Permit - Commercial  
Address: 200 NE MISSOURI RD, Unit:103, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Partial	Friday, March 13, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ SECOND FLOOR @ FOLLOWING LOCATIONS: GWB SOFFIT AT RECEPTION AREA; SOFFITS-RM-110,111,112,113,116,118,119,120,124,104,105,123	
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Friday, March 13, 2015
Corrective Action Required 1 FIRST FLOOR		FIREWALL 1ST LAYER-SCREW PATTERN ROOMS-114,115,121,123,124	

**Comments:**